

# EV6412J/EV6412M Two outputs digital thermoregulators for general purposes

## GB ENGLISH

### 1 GETTING STARTED


#### 1.1 Important

Read these instructions carefully before installing and using the instrument and follow all additional information for installation and electrical connection; keep these instructions close to the instrument for future consultations.

**The instrument must be disposed according to the local legislation about the collection for electrical and electronic equipment.**


#### 1.2 Size

3 DIN modules; size in mm (in).



#### 1.3 Installation



On DIN rail.



Additional information for installation:

- working conditions (working temperature, humidity, etc.) must be between the limits indicated in the technical data
- do not install the instrument close to heating sources (heaters, hot air ducts, etc.), devices provided with big magnetos (big speakers, etc.), locations subject to direct sunlight, rain, humidity, dust, mechanical vibrations or bumps
- according to the safety legislation, the protection against electrical parts must be ensured by a correct installation of the instrument; the parts that ensure the protection must be installed so that you can not remove them if not by using a tool.

#### 1.4 Wiring diagram



With reference to the wiring diagram:

- the serial port (by request) is the port for the communication with the supervision system (through a serial interface, via TTL, with MODBUS communication protocol) or with the programming key; the port must not be used at the same time for the same purposes.
- Additional information for electrical connection:
  - do not operate on the terminal blocks with electrical or pneumatic screws
  - if the instrument has been moved from a cold location to a warm one, the humidity could condense on the inside; wait about an hour before supplying it
  - test the working power supply voltage, working electrical frequency and working electrical power of the instrument; they must correspond with the local power supply
  - disconnect the local power supply before servicing the instrument
  - provide the thermocouple with a protection cable to protect it against contacts with metal parts or use insulated thermocouples
  - do not use the instrument as safety device
  - for repairs and information on the instrument please contact Evco sales network.

#### 2 USER INTERFACE

##### 2.1 Turning on/off the instrument

To turn on the instrument you have to supply it; to turn it off it is enough to cut off the power supply.

##### 2.2 The display

If the instrument is turned on, during the normal operation the display will show the quantity you have set with parameter P5:

- if P5 = 0, the display will show the room temperature
- if P5 = 1, the display will show the first working setpoint.

##### 2.3 Showing the room temperature

- make sure the keyboard is not locked and no procedure is running
- press **set** 2 s: the display will show "Pb1"
- press **set**

To quit the procedure:

- press **set** or do not operate 60 s
- press **set** or **▼** as long as the display shows the quantity you have set with parameter P5 or do not operate 60 s.

##### 2.4 Locking/unlocking the keyboard

To lock the keyboard:

- make sure no procedure is running
- press **set** and **▼** 2 s: the display will show "Loc" 1 s.
- If the keyboard is locked, you will not be allowed to:
  - modify the working setpoints with the procedures related in paragraphs 4.1 and 4.2 (you also can modify the working setpoints through parameters SP1 and SP2).

This operation provokes the visualization of the label "Loc" 1 s.

To unlock the keyboard:

- press **set** and **▼** 2 s: the display will show "UnL" 1 s.

##### 2.5 Silencing the buzzer

- make sure no procedure is running
- press a button (the first pressure of the button does not provoke its usual effect).

#### 3 OPERATION

##### 3.1 Preliminary information

The operation mainly depends on parameter CFG.

##### 3.2 Operation with parameter CFG = 1 (the first working setpoint is independent and the second one is relative to the first)

If parameter CFG has value 4, the second working setpoint will not be available and parameters SP2, r0, r6, r7, r8, r9 and r10 will not be significant.

You can get each load to work for cooling (parameter r5 = 0) or for heating (parameter r5 = 1); parameter r5 sets the action for each load.

In this example each load works for cooling.

##### 4 SETTINGS

###### 4.1 Setting the first working setpoint

- make sure the keyboard is not locked and no procedure is running
- press **set** LED **out 1** will flash
- press **set** or **▼** in 15 s; also look at parameters r1, r2 and r3
- do not operate 15 s.

You also can modify the first working setpoint through parameter SP1.

###### 4.2 Setting the second working setpoint

- press **set** during the modification of the first working setpoint: LED **out 2** will flash
- press **set** or **▼** in 15 s; also look at parameters r7, r8 and r9
- press **set** or do not operate 15 s.

You also can modify the second working setpoint through parameter SP2.

If parameter CFG has value 1, you can set the second working setpoint through parameter SP2 only (because it is relative to the first one).


If parameter CFG has value 3 or 4, the second working setpoint will not be available.

###### 4.3 Setting configuration parameters

To gain access the procedure:

- make sure no procedure is running
- press **set** and **▼** 4 s: the display will show "PA"
- press **set**
- press **set** or **▼** in 15 s to set "-19"
- press **set** or do not operate 15 s
- press **set** and **▼** 4 s: the display will show "SP1".

### 3.3 Operation with parameter CFG = 2 (two independent working setpoints)



To select a parameter:

- press **▲** or **▼**
- To modify a parameter:
  - press **set**
  - press **▲** or **▼** in 15 s
  - press **set** or do not operate 15 s.

To quit the procedure:

- press **set** and **▼** 4 s or do not operate 60 s.

### Switch off/on the power supply of the instrument after the modification of the parameters.

### 4.4 Restoring the default value of configuration parameters

- make sure no procedure is running
- press **set** and **▼** 4 s: the display will show "PA"
- press **set**
- press **set** or **▼** in 15 s to set "743"
- press **set** or do not operate 15 s
- press **set** and **▼** 4 s: the display will show "DEF"
- press **set**
- press **set** or **▼** in 15 s to set "149"
- press **set** or do not operate 15 s: the display will show "DEF" flashing 4 s, after which the instrument will quit the procedure
- switch off/on the power supply of the instrument.

### Make sure the default value of the parameters is appropriate, in particular if the probes are not Pt 100 probes.

#### 5 SIGNALS

##### 5.1 Signals

LED	MEANING
<b>out 1</b>	LED load 1 if it is lit, load 1 will be turned on if it flashes: the modification of the first working setpoint will be running a load 1 protection will be running (parameters C1 and C2)
<b>out 2</b>	LED load 2 if it is lit, load 2 will be turned on if it flashes: the modification of the second working setpoint will be running a load 2 protection will be running (parameters C7 and C8)

##### LED alarm

- if it is lit, an alarm will be running

##### °C

- if it is lit, the unit of measure of the temperatures will be Celsius degree (parameter P2)

##### °F

- if it is lit, the unit of measure of the temperatures will be Fahrenheit degree (parameter P2)

##### CODE

- the keyboard and/or the working setpoints are locked (parameters r3 and/or r9); also look at paragraph 2.4

#### 6 ALARMS

##### 6.1 Alarms

CODE	MEANING
<b>AL1</b>	First temperature alarm Remedies: check the room temperature look at parameters A1 and A3 Effects: no effect

CODE	MEANING
<b>AL2</b>	Second temperature alarm Remedies: check the room temperature look at parameters A5 and A7 Effects: no effect

When the cause that has provoked the alarm disappears, the instrument restores the normal operation.

#### 7 INTERNAL DIAGNOSTICS

##### 7.1 Internal diagnostics

CODE	MEANING
<b>PR1</b>	Room probe error Remedies: look at parameter P0 check the integrity of the probe check the connection instrument-probe check the room temperature Effects: load 1 activity will depend on parameter C6 load 2 activity will depend on parameter C10

When the cause that has provoked the alarm disappears, the instrument restores the normal operation.

#### 8 TECHNICAL DATA

##### 8.1 Technical data

**Box:** self-extinguishing grey.

**Frontal protection:** IP 54.

**Connections:** screw terminal blocks (power supply, input and outputs), 6 poles connector (serial port; by request).

**Working temperature:** from 0 to 55 °C (32 to 131 °F, 10 ... 90% of relative humidity without condensate).

**Power supply:** 230 VAC, 50/60 Hz, 3 VA (approximate); 115 VAC or 24 VAC or 12-24 VAC/DC or 12 VAC/DC by request.

**Alarm buzzer:** by request.

**Measure inputs EV6412J:** 1 (room probe) for J/K thermocouples.

**Measure inputs EV6412M:** 1 (room probe) for PTC/NTC probes, J/K thermocouples, 2/3 wires Pt 100, Pt 1000 and Ni 120 probes, 0-20/4-20 mA and 0-10/2-10 V transducers (universal measure input).

**Working range:** from -50 to 150 °C (-50 to 300 °F) for PTC probe, from -40 to 110 °C (40 to 230 °F) for NTC probe, from -100 to 800 °C (-140 to 1,450 °F) for J thermocouple, from -100 to 1,300 °C (-140 to 1,999 °F) for K thermocouple, from -200 to 650 °C (-320 to 1,200 °F) for 2/3 wires Pt 100 probe, from -80 to 300 °C (-110 to 570 °F) for 2/3 wires Ni 120 probe.

**Resolution:** 0.1 °C/1 °C/1 °F.

**Digital outputs:** 2 relays:

- Load 1 relay:** 16 res. A @ 250 VAC (change-over contact)
- Load 2 relay:** 8 res. A @ 250 VAC (change-over contact).

**The maximum current allowed on load 1 is 10 A**

**Serial port:** port for the communication with the supervision system (through a serial interface, via TTL, with MODBUS communication protocol) or with the programming key; by request.

**Per uscire dalla procedura:**

- premere **set** o non operare per 60 s

- premere ▲ o ▼ entro 15 s
  - premere set o non operare per 15 s.
- Per uscire dalla procedura:
- premere ▲ e ▼ per 4 s o non operare per 60 s.

#### **Interrompere l'alimentazione dello strumento dopo la modifica dei parametri.**

#### **4.4 Ripristino del valore di default dei parametri di configurazione**

- assicurarsi che non sia in corso alcuna procedura
- premere ▲ e ▼ per 4 s: il display visualizzerà "PA"
- premere set
- premere ▲ o ▼ entro 15 s per impostare "743"
- premere set o non operare per 15 s
- premere ▲ e ▼ per 4 s: il display visualizzerà "DEF"
- premere set
- premere ▲ o ▼ entro 15 s per impostare "149"
- premere set o non operare per 15 s: il display visualizzerà "DEF" lampeggiante per 4 s, dopodiché lo strumento uscirà dalla procedura
- interrompere l'alimentazione dello strumento.

**Accertarsi che il valore di default dei parametri sia oppure, in particolare se le sonde non sono di tipo Pt 100.**

#### **5 SEGNALAZIONI**

##### **5.1 Segnalazioni**

LED	SIGNIFICATO
out 1	LED carico 1 se è acceso, il carico 1 sarà acceso se lampeggia: ▪ sarà in corso la modifica del primo setpoint di lavoro ▪ sarà in corso una protezione del carico 1 (parametri C1 e C2)
out 2	LED carico 2 se è acceso, il carico 2 sarà acceso se lampeggia: ▪ sarà in corso la modifica del secondo setpoint di lavoro ▪ sarà in corso una protezione del carico 2 (parametri C7 e C8)
▲	LED allarme se è acceso, sarà in corso un allarme
°C	LED grado Celsius se è acceso, l'unità di misura delle temperature sarà il grado Celsius (parametro P2)
°F	LED grado Fahrenheit se è acceso, l'unità di misura delle temperature sarà il grado Fahrenheit (parametro P2)
CODICE	SIGNIFICATO
Loc	la tastiera e/o i setpoint di lavoro sono bloccati (parametri r3 e/o r9); si veda il paragrafo 2.4

#### **6 ALLARMI**

##### **6.1 Allarmi**

CODICE	SIGNIFICATO
AL1	Primo allarme di temperatura Rimedi: ▪ verificare la temperatura dell'ambiente ▪ si vedano i parametri A1 e A3

#### **GB ENGLISH**

##### **9 WORKING SETPOINTS AND CONFIGURATION PARAMETERS**

9.1 Working setpoints				
MIN.	MAX.	U.M.	DEF	WORKING SETPOINTS
r1	r2	°C/F (I)	0.0	first working setpoint
r7	r8	°C/F (I)	0.0	second working setpoint
9.2 Configuration parameters				
PARAM.	MIN.	MAX.	U.M.	DEF
SP1	r1	°C/F (I)	0.0	first working setpoint
SP2	r7	°C/F (I)	0.0	second working setpoint
PARAM.	MIN.	MAX.	U.M.	DEF
CA1	-25.0	25.0	°C/F (I)	0.0
P0	0	13	---	room probe offset

P1	0	1	---	1	if P0 = 0 ... 7 or 12 ... 13, decimal point Celsius 0 = YES if P0 = 8 ... 11, decimal point position 0 = no decimal point 1 = on the digit of ten	se P0 = 0 ... 7 o 12 ... 13, punto decimale grado Celsius 1 = SI se P0 = 8 ... 11, posizione del punto decimale 0 = nessun punto decimale 1 = sul digit delle decine
P2	0	2	---	0	unit of measure temperature (influential only on LED Celsius degree and on LED Fahrenheit if P0 = 8 ... 11) (3) (4) 0 = °C 1 = °F	unità di misura temperatura (influenza solo sul LED Celsius degree e sul LED grado Fahrenheit se P0 = 8 ... 11) (3) (4) 0 = °C 1 = °F

Conseguenze: ▪ lo strumento continuerà a funzionare regolarmente				
<b>AL2</b> Secondo allarme di temperatura Rimedi: ▪ verificare la temperatura dell'ambiente ▪ si vedano i parametri A5 e A7 Conseguenze: ▪ lo strumento continuerà a funzionare regolarmente				
Quando la causa che ha provocato l'allarme scompare, lo strumento ripristina il normale funzionamento.				
<b>7 DIAGNOSTICA INTERNA</b>				
<b>7.1 Diagnistica interna</b>				

##### **CODICE SIGNIFICATO**

##### **Pr1** Errore sonda ambiente

Rimedi:

- si veda il parametro P0
- verificare l'integrità della sonda
- verificare il collegamento strumento-sonda
- verificare la temperatura dell'ambiente

Conseguenze:

- l'attività del carico 1 dipenderà dal parametro C6
- l'attività del carico 2 dipenderà dal parametro C10

Quando la causa che ha provocato l'allarme scompare, lo strumento ripristina il normale funzionamento.

##### **8 DATI TECNICI**

##### **8.1 Dati tecnici**

**Contenitore:** autoestinguente grigio.

**Grado di protezione del frontale:** IP 54.

**Connessioni:** morsetti a vite (alimentazione, ingresso e uscite), connettore a 6 poli (porta seriale; su richiesta).

**Temperatura di impiego:** da 0 a 55 °C (10 ... 90% di umidità relativa senza condensa).

**Alimentazione:** 230 VCA, 50/60 Hz, 3 VA (approssimativi); 115 VCA o 24 VCA o 12-24 VCA/CC o 12 VCA/CC su richiesta.

**Buzzer di allarme:** su richiesta.

**Ingressi di misura EV6412J:** 1 (sonda ambiente) per termocoppe J/K.

**Ingressi di misura EV6412M:** 1 (sonda ambiente) per sonde PTC/NTC, termocoppe J/K, sonde Pt 100, Pt 1000 e Ni 120 2/3 fili, trasduttori 0-20/4-20 mA e 0-10V-10V (ingresso di misura universale).

**Campo di misura:** da -50 a 150 °C per sonda PTC, da -40 a 110 °C

per sonda NTC, da -100 a 800 °C per termocoppia J, da -100 a

1.300 °C per termocoppia K, da -200 a 650 °C per sonda Pt 100 2/3 fili,

da -200 a 650 °C per sonda Pt 1000 2/3 fili, da -80 a 300 °C per sonda Ni 120 2/3 fili.

**Risoluzione:** 0,1 °C/1 °C/1 °F.

**Uscite digitali:** 2 relè:

- **relè carico 1:** 16 A res. @ 250 VCA (contatto in scambio)

- **relè carico 2:** 8 A res. @ 250 VCA (contatto in scambio).

**La corrente massima consentita sul carico 1 è di 10 A.**

**Porta seriale:** porta per la comunicazione con il sistema di supervisione (attraverso un'interfaccia seriale, via TTL, con protocollo di comunicazione MODBUS) o con la chiave di programmazione; su richiesta.

				2 = LED Celsius degree and LED Fahrenheit degree will remain turned off	2 = il LED grado Celsius e il LED grado Fahrenheit rimarranno spenti
P3	-199.0	199.0	points	-20.0	minimum value of the range of the transducer
P4	-199.0	199.0	points	80.0	maximum value of the range of the transducer
P5	0	1	---	0	quantity to show during the normal operation 0 = room temperature 1 = first working setpoint
					0 = temperatura dell'ambiente 1 = primo setpoint di lavoro
					REGOLATORI
PARAM.	MIN.	MAX.	U.M.	DEF.	REGULATORS
r0	0.1	99.0	°C/F (I)	2.0	if CFG = 1 or 2, first working setpoint differential if CFG = 3, differential of the load working for cooling (load 1)
r1	-199.0	r2	°C/F (I)	0.0	minimum first working setpoint
r2	r1	[5]	°C/F (I)	350.0	maximum first working setpoint
r3	0	1	---	0	locking the first working setpoint modification (with the procedure related in paragraph 4.1) 1 = YES
r5	0	1	---	1	if CFG = 1 or 2, cooling or heating action load 1 if CFG = 4, cooling or heating action loads 0 = cooling
r6	0.1	99.0	°C/F (I)	2.0	if CFG = 1 or 2, second working setpoint differential if CFG = 3, differential of the load working for heating (load 2)
r7	-199.0	r8	°C/F (I)	0.0	minimum second working setpoint
r8	r7	[5]	°C/F (I)	350.0	maximum second working setpoint
r9	0	1	---	0	locking the second working setpoint modification (with the procedure related in paragraph 4.2) 1 = YES
r10	0	1	---	1	cooling or heating action load 2 (only if CFG = 1 or 2) 0 = cooling
r11	1.0	[5]	°C/F (I)	5.0	if CFG = 3, neutral zone value if CFG = 4, value of two steps
PARAM.	MIN.	MAX.	U.M.	DEF.	LOADS PROTECTIONS
C1	0	240	min	0	minimum time between two activations in succession of load 1; also load 1 delay since the end of the room probe error [6]
C2	0	240	min	0	minimum time load 1 remains turned off; also load 1 delay since you turn on the instrument
C3	0	240	s	0	minimum time load 1 remains turned on
C6	0	1	---	0	load 1 activity during the room probe error 0 = turned off 1 = turned on
C7	0	240	min	0	minimum time between two activations in succession of load 2; also load 2 delay since the end of the room probe error [6]
C8	0	240	min	0	minimum time load 2 remains turned off; also load 1 delay since you turn on the instrument
C9	0	240	s	0	minimum time load 2 remains turned on
C10	0	1	---	0	load 2 activity during the room probe error 0 = turned off 1 = turned on
PARAM.	MIN.	MAX.	U.M.	DEF.	TEMPERATURE ALARMS
A1	-199.0	[5]	°C/F (I)	0.0	temperature the first temperature alarm is activated; also look at A3 (7)
A2	0	240	min	0	first temperature alarm delay
A3	0	4	---	0	kind of first temperature alarm 0 = alarm not enabled 1 = absolute lower alarm (or A1) 2 = absolute upper alarm (or A1) 3 = lower alarm relative to the first working setpoint (or "first working setpoint-A1"; consider A1 without sign)
					4 = upper alarm relative to the first working setpoint (or "first working setpoint + A1"; consider A1 without sign)
A4	0	240	min	0	temperature alarms delay since an independent working setpoint modification
A5	-199.0	[5]	°C/F (I)	0.0	temperature the second temperature alarm is activated; also look at A7 (7)
A6	0	240	min	0	second temperature alarm delay</